

COMMISSIONERS
Lea Márquez Peterson – Chairwoman
Sandra D. Kennedy
Justin Olson
Anna Tovar
Jim O'Connor



Matthew J. Neubert
Executive Director

Elijah O. Abinah
Utilities Division Director

ARIZONA CORPORATION COMMISSION

June 1, 2022

Jay L. Shapiro
Sunrise Vistas Utilities Company
Shapiro Law Firm, P.C.
1819 East Morten Avenue, Suite 280
Phoenix, Arizona 85020

RE: **SUNRISE VISTAS UTILITIES COMPANY**
DOCKET NO. WS-03586A-22-0115

Notice of Administrative Approval/Closure

Dear Mr. Shapiro:

Enclosed is a stamped copy of the tariffs that becomes effective by operation of law on June 13, 2022

By copy of this letter, the Docket Control Center is requested to administratively close Docket No. WS-03586A-22-0115. If you have questions regarding the filing of these tariffs, please contact me at (602) 542-1255.

Sincerely,

Cam Aten
Utilities Engineer
Utilities Division

CA:ihf

Attachments

On this 1st day of June, 2022, the foregoing document was filed with Docket Control as a Letter Directing Administrative Closure - Tariff, and copies of the foregoing were mailed on behalf of the Utilities Division to the following who have not consented to email service. On this date or as soon as possible thereafter, the Commission's eDocket program will automatically email a link to the foregoing to the following who have consented to email service.

Jay Shapiro
Shapiro Law Firm, P.C.
1819 East Morten Avenue, Suite 280
Phoenix, Arizona 85020
jay@shaplawaz.com
Consented to Service by Email

Robin Mitchell
Director/Chief Counsel, Legal Division
Arizona Corporation Commission
1200 West Washington Street
Phoenix, Arizona 85007
legaldiv@azcc.gov
utildivservicebyemail@azcc.gov
Consented to Service by Email

By: *Isabelle Fuga*
Isabelle Fuga
Administrative Support Specialist

CROSS-CONNECTION OR BACKFLOW TARIFF

PURPOSE:

The purpose of this tariff is to protect Sunrise Vistas Utilities Company's ("Company") water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6 and A.A.C. R18-4-215.

REQUIREMENTS:

In compliance with the Rules of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-215 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-215.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-215.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff.
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a is **not** applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the backflow-prevention assembly within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

Issued: May 13, 2022

ISSUED BY:

Effective:

Jason Williamson
Sunrise Vistas Utilities Company
7581 E. Academy Boulevard, Suite 229
Denver, Colorado 80230

**ADMINISTRATIVELY
APPROVED FOR FILING**

-
5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
 6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location;
 - c. date(s) of test(s);
 - d. description of repairs and recommendations for repairs made by tester; and
 - e. the tester's name and certificate number.
 7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
 8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

Issued: May 13, 2022

ISSUED BY:

Effective:

Jason Williamson
Sunrise Vistas Utilities Company
7581 E. Academy Boulevard, Suite 229
Denver, Colorado 80230

**ADMINISTRATIVELY
APPROVED FOR FILING**